



1. Материал / Materjal: 1.4826
2. Раковины не допускаются / Tühikud ei ole lubatud
3. Точность отливки / Valmistäpsus EN ISO 8062-3 DCTG6 - GCTG6
4. Неуказанные допуски на механическую обработку EN ISO 2768-m-K / Mehhaanilise töödeldud pindade mõõdete täpsustamata piirhälved EN ISO 2768- järgi.

 Enefit Energiatootmine AS			Реконструкция крепления сопел охлаждения	Mass, kg												
			монки CFB KW01-HX001 / CFB KW01-HX001	6,5 кг												
We reserve all rights in this document and in the information contained therein. Reproduction, use or disclosure to third parties without express authority is strictly forbidden. Enefit Energiatootmine AS			Project kolde düüside rekonstrueerimine	Scale												
Order: Enefit 280			KKS code: KW01-HX001-GS01	1 : 2												
Title			Сопло монки CFB / CFB kolde	Size												
<table border="1"> <tr> <td>Performers</td> <td>Signature</td> <td>Date</td> </tr> <tr> <td>Drawn Feliks Karlovski</td> <td></td> <td>28.02.2018</td> </tr> <tr> <td>Checked Sergei Jepifanov</td> <td></td> <td></td> </tr> <tr> <td>Approved Andrei Stolbov</td> <td></td> <td></td> </tr> </table>			Performers	Signature	Date	Drawn Feliks Karlovski		28.02.2018	Checked Sergei Jepifanov			Approved Andrei Stolbov			düüs	Page / Pages
Performers	Signature	Date														
Drawn Feliks Karlovski		28.02.2018														
Checked Sergei Jepifanov																
Approved Andrei Stolbov																
DWG No			EN2-00266.01.01	1 / 1												
			Rev.	01												